



NOTES:

- 1. CONCRETE PROTECTIVE SLAB SHALL BE 2500 P.S.I. WITH 6"X6"-10/10 W.W. MESH AND 12" MIN. BEARING EACH SIDE OF TRENCH.
- 2. PROTECTIVE SLAB REQUIRED WHERE COVER FOR MAINS IS LESS THAN 30" AND LATERALS WHEN LESS THAN 24".

LBPH INC. - CADD FILE NAME: L:\CAD-DETAILS\SLC\SLC-G1.DWG



**ST. LUCIE COUNTY
WATER & WASTEWATER
CONSTRUCTION STANDARDS**

PROTECTIVE SLAB FOR PIPE