



NOTES:

- 1 MIN. SERVICE LINES SHALL BE AS FOLLOWS: 1" FOR SINGLE AND DOUBLE SERVICES WHERE METER SIZE IS 5/8"; 1 1/2" FOR SINGLE AND DOUBLE SERVICES WHERE METER SIZE IS 1".
- 2 COMPRESSION FITTINGS SHALL BE SUITABLE FOR TUBING USED AND REQUIRE METAL (S.S.) INSERTS.
- 3 DOUBLE SERVICES REQUIRE "U" BRANCH WITH ANGLE CURB STOPS.
- 4 POLYBUTYLENE SHALL BE AS DEFINED BY A.S.T.M. D2666 SDR9 AND A.W.W.A. 902, LATEST EDITION, AND BE PRESSURE RATED FOR 250 PSI.
- 5 POLYETHYLENE SHALL BE AS DEFINED BY A.S.T.M. D2737 SDR9 AND A.W.W.A. 901, LATEST EDITION, AND BE PRESSURE RATED FOR 200 PSI.
- 6 TUBING SHALL BE MARKED WITH SIZE, MANUFACTURERS NAME, WORKING PRESSURE, NATIONAL SANITATION FOUNDATION APPROVAL, A.S.T.M. SPECIFICATION AND PRODUCTION CODE. TUBING SHALL HAVE AN OUTSIDE DIAMETER EQUIVALENT TO THE OUTER DIAMETER OF COPPER TUBING.

LBPH INC. - CADD FILE NAME: L:\CAD-DETAILS\SLC\SLC-W1.DWG



ST. LUCIE COUNTY
WATER & WASTEWATER
CONSTRUCTION STANDARDS

SERVICE CONNECTION DETAIL
5/8" OR 1" METER

DRAWING NUMBER: W-1