



**NOTES:**

1. ALL VALVES TO BE STRAIGHT 2" BALL VALVES WITH LOCK-WING. (FLANGE AT METER) FORD BF 83-777 WG OR APPROVED EQUAL.
2. SEE TYPICAL SERVICE DETAIL FOR MAIN CONNECTION.
3. METER BOX SHALL BE POLYMER CONCRETE AND FIBER REINFORCED POLYESTER.
4. PIPING SHALL BE 2" SCHEDULE 80 PVC WITH SCHEDULE 80 FITTINGS.

LBFH INC. - CADD FILE NAME: L:\CAD-DETAILS\SLC\SLC-W2.DWG



**ST. LUCIE COUNTY  
WATER & WASTEWATER  
CONSTRUCTION STANDARDS**

**2" METER DETAIL**

DRAWING NUMBER: **W-2**