



MATERIALS

ITEM	QUANT.	DESCRIPTION
1	1	2" BACKFLOW PREVENTER
2	3	2" X 4" NIPPLES
2A	1	2" X NOM. NIPPLE
3	1	2" COUPLING - COMPRESSION
4	2	2" X 90° ELBOW
5	4	2" X 6" NIPPLES
6	4	GATE VALVE (BRONZE)
7		PEA GRAVEL
8		FILTER FABRIC
9		FINISHED GRADE
10	1	2" WYE STRAINER

- NOTES:** 1. INSTALLATION SHOWN ABOVE IS FOR A 2" SERVICE. CHANGE PIPING MATERIALS ACCORDINGLY FOR SERVICE SIZE.
 2. CUT ENDS OF ITEM 2A IN THE FIELD.
 3. TEST COCK ON VALVE FOR DOUBLE CHECK.
 4. USE COPPER, BRASS OR STAINLESS STEEL FOR FITTINGS AND PIPE MATERIAL.

LBFH INC. - CADD FILE NAME: L:\CAD-DETAILS\SLC\SLC-W9.DWG



ST. LUCIE COUNTY
 WATER & WASTEWATER
 CONSTRUCTION STANDARDS

DOUBLE CHECK OR REDUCED
 PRESSURE BACKFLOW
 PREVENTER SINGLE SERVICE
 3/4" TO 2"

DRAWING NUMBER: **W-9**