



NOTES:

1. ALL DETAILS AND SPECIFICATIONS FOR STANDARD MANHOLES ARE APPLICABLE EXCEPT FOR REFERENCES TO DROP ASSEMBLY.
2. DROP CONNECTIONS SHALL BE REQUIRED WHENEVER AN INFLUENT INVERT IS LOCATED 2.5 FEET OR MORE ABOVE THE MAIN INVERT CHANNEL. DROP CONNECTIONS SHOULD NOT BE DESIGNED FOR LESS THAN A 2.5 FOOT DROP.

LBFH INC. - CADD FILE NAME: L:\CAD-DETAILS\SLC\SLC-WW14.DWG



**ST. LUCIE COUNTY
WATER & WASTEWATER
CONSTRUCTION STANDARDS**

**SERVICE DROP
INTO MANHOLE**

DRAWING NUMBER: **WW-14**