



NOTES:

1. FENCED AREA TO BE COVERED WITH 2 PLY 40 VISQUEEN AND A MINIMUM OF 6" THICK, 3/4" DIAMETER WASHROCK
2. INFLUENT MAIN SHALL BE CLEAR OF PANEL AND VAULT.
3. WATER SERVICE TO L.S. MUST BE SUPPLIED WITH 1-1/2" R.P.Z. BACKFLOW PREVENTER INSIDE FENCE.
4. ACCESS ROAD TO HAVE 12" STABILIZED SUBBASE COMPACTED TO 98% MAXIMUM DENSITY AS DETERMINED BY AASHTO T-180, ADD EITHER 8" CONCRETE OR 8" BASE COMPACTED TO 100% MAXIMUM DENSITY AS DETERMINED BY AASHTO T-180 WITH 2" ASPHALT.

LBFH INC. - CADD FILE NAME: L1/CAD-DETAILS/SLC/SLC-WW22.DWG



**ST. LUCIE COUNTY
WATER & WASTEWATER
CONSTRUCTION STANDARDS**

**TYPICAL LIFT STATION
LAYOUT DETAIL**

DRAWING NUMBER: **WW-22**