

ST. LUCIE COUNTY UTILITIES
North County WATER SYSTEM
(SLCU NWCS)
PWS ID# 4561689
2019 ANNUAL DRINKING
WATER QUALITY REPORT

Este informe contiene información muy importante sobre su agua beber. Tradúscalo ó líable con un amigo quien lo entienda bien.

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. If you have any questions or concerns about the information provided in this report, please feel free to call any of the numbers listed.

WHERE YOUR WATER COMES FROM

The source for the Holiday Pines water treatment plant is ground water which is withdrawn from wells in the Surficial Aquifer. The water is treated by reverse osmosis and disinfected. It is blended with the water purchased from Ft. Pierce Utilities Authority (FPUA). That source is ground water which is withdrawn from wells in the Floridan and Surficial Aquifers. The water is treated by conventional lime softening, aeration, and sand filtration and reverse osmosis. The water is then disinfected, and fluoride is added to prevent tooth decay prior to delivery to customers.

HOW WE ENSURE YOUR DRINKING WATER IS SAFE

We are pleased to report that our drinking water meets all federal and state requirements. St. Lucie County Utilities and FPUA routinely monitor for contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2019. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old but are based on the most recent water analyses performed.

ADDITIONAL HEALTH INFORMATION

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

(A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

(B) Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

(C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

(D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

(E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

HOW TO READ THE TABLE

The terms used in the water quality summary table and in other parts of this report are defined below.

Action level (AL) – the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Locational Running Annual Average (LRAA) – the average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Maximum contaminant level or MCL – the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum contaminant level goal or MCLG – the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL – the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG – the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

N/A – not applicable

ND – means not detected and indicates that the substance was not found by laboratory analysis

ppm – parts per million or milligrams per liter is one part by weight of analyte to one million parts by weight of the water sample.

ppb – parts per billion or micrograms per liter is one part by weight of analyte to one billion parts by weight of the water sample.

**FOR CUSTOMERS WITH
SPECIAL HEALTH CONCERNS**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

HOW TO REACH US

If you have any questions about this report or concerning your water utility, please contact St. Lucie County Utilities at 772-462-1150. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Board of County Commissioner meetings. They are normally held each month on the 1st Tuesday at 6 pm and the 2nd and 3rd Tuesday at 9 am at the County Commission Chambers.

SOURCE WATER ASSESSMENT PLAN

The Florida Department of Environmental Protection (FDEP) performed a Source Water Assessment on the SLCU NCWS in 2019. The assessment was conducted to provide information about any potential sources of contamination near the all the wells. There are 9 potential sources of contamination identified for this system with a low to moderate susceptibility level. The assessment results are available on the FDEP Source Water Assessment and Protection Program website at www.dep.state.fl.us/swapp. FPUA has built treatment systems as a result of those potential sources of contamination.

2019 WATER QUALITY SUMMARY TABLE – PWS ID NO. 4561689

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected ^A	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Inorganic Contaminants							
Arsenic (ppb)	5/17	N	0.72	0.58 – 0.72	0	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Chromium (ppb)	5/17	N	0.77	ND – 0.77	100	100	Discharge from steel and pulp mills; erosion of natural deposits.
Barium (ppm)	5/17	N	0.0049	0.0024 – 0.0049	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Cyanide (ppb)	12/38	N	6.3	ND – 6.3	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer
Fluoride (ppm)	1/18 – 12/18	N	0.76	ND – 0.76	4	4	Erosion of natural deposits; discharge from fertilizer and aluminum factories. Water additive which promotes strong teeth when at the optimum level of 0.7 ppm.
Sodium (ppm)	5/17	N	49.2	47.9 – 60.6	N/A	160	Salt water intrusion, leaching from soil
Nitrate (as Nitrogen) (ppm)	12/19	N	0.67	N/A	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (as Nitrogen) (ppm)	12/19	N	0.43	N/A	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Stage 1 Disinfectants and Disinfection By-Products							
Chlorine and chloramines (ppm)	1/19 – 12/19	N	1.66	0.40 – 5.30	4	4.0	Water additive used to control microbes
Stage 2 Disinfectants and Disinfection By-Products							
TTHMs (Total trihalomethanes) (ppb)	9/19 – 12/19	N	48.45	27.7 – 64.1	N/A	60	By-product of drinking water disinfection
HAA5s (Haloacetic acids) (five) (ppb)	9/19 – 12/19	N	31.60	8.63 – 34.3	N/A	80	By-product of drinking water disinfection
Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	AL Exceeded Y/N	90th Percentile Result	No. of sampling sites exceeding the AL	MCLG	AL (Action Level)	Likely Source of Contamination
Lead and Copper (Tap Water)							
Copper (tap water) (ppm)	4/18	N	0.625	0	1.3	AL = 1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppb) ^B	4/18	N	4.2	1	0	AL = 15	Corrosion of household plumbing systems, erosion of natural deposits

TABLE NOTES:

- A. Results in the level detected column for inorganic contaminants, trihalomethanes, and haloacetic acids are the highest detected level or the highest average at any sampling point, depending on the sampling frequency, except for fluoride which is a running annual average (RAA). The result in the level detected column for chlorine and chloramines is the highest RAA, computed quarterly, of the monthly averages of all samples collected. The result in the level detected column for copper is the 90th percentile of all sample results for the most recent round of sampling. The range of results is the range of lowest to highest results at the individual sampling sites. The sample results shown in the table above represent samples taken in the FPUA water system except for Stage 2 Disinfectants and Disinfection By-Products and lead and copper which represent samples taken in the St. Lucie County North water system.
- B. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The St. Lucie County North water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.